Office of the FIRE STATION OFFICER,
Karnataka Fire and Emergency Services Department
Fire station, Molakalmuru -577535

Phone:08198-200100 **fsomolakalmuru.ksfes@ka.gov.in**

C.No: 09/SCHOOL/FSR/FSO/MLK/2026 **Date: 30-09-2026**

To,

The District Fire officer,
Karnataka State Fire & Emergency services,
Medehalli road,
Chitradurga District-577502.

Sir,

Sub: Submitting the inspection report for Issuing ***'Fire Advisory Certificate'*** to ***"Sri Guru Mudukeshwara Higher Primary & High School"***, situated at ***Survey No: 55/1, Behind Indian Petrol Bunk, B.B Road, Rampura Village, Molakalmuru Taluk, Chitradurga - 577540.***

Ref: C.No:88/School/FSR/DFO/2025 & GSC No: FR099-00002-03506, Date: 24-09-2026

****

With reference to the subject above cited the premises of ***"Sri Guru Mudukeshwara Higher Primary & High School"***, situated at ***Survey No: 55/1, Behind Indian Petrol Bunk, B.B Road, Rampura Village, Molakalmuru Taluk, Chitradurga - 577540*** was inspected by Fire station officer, Molakalmuru on **29-09-2026** with respect to Fire prevention, Firefighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

Details of the Building/Premises.

Part-A: General Building Requirements		
01	Name and Address of the Applicant	The Secretary, Sri Guru Mudukeshwara Vidyapeeta ®, Sri Guru Mudukeshwara Higher Primary & High School, Rampura village, Molakalmuru Taluk, Chitradurga district-577540
02	Name and Address of the Premises	Survey No: 55/1, Sri Guru Mudukeshwara Vidyapeeta ®, Sri Guru Mudukeshwara Higher Primary & High School, Behind Indian Petrol Bunk, B.B Road, Rampura Village, Molakalmuru Taluk, Chitradurga district-577535
03.	Name and Address of the Building Owner	The Secretary, Sri Guru Mudukeshwara Vidyapeeta ®, Sri Guru Mudukeshwara Higher Primary & High School, Rampura village, Molakalmuru Taluk, Chitradurga district-577540
04.	Number of Building	One Building
05.	Dise Code	29130607714
06.	Number of Floors	Ground and 02 Upper Floor

Scanned with OKEN Scanner

07.	**Floor-wise details of Occupancy: -**	
	Ground Floor	01 Office Room, 03 Labs & 05 Class Rooms
	1st floor	08 Class Rooms & 01 Staff Room
	2nd Floor	College Section, 08 Class Rooms & 01 Staff Room
08.	Height of the building	**10.75 mtrs**
09.	Site area	**14,265.17 Sq. Mtrs (3.50 Acres)**
10.	**Built-up area of each floor: -**	
	Ground floor	638.54 Sq. mtrs
	1st floor	638.54 Sq. mtrs
	2nd floor	638.54 Sq. mtrs
11.	Total Built-up area	**1915.62 Sq. mtrs**
12.	**Surrounding properties: -**	
	East (Front)	Residential building
	West (Rear)	Agricultural land
	North (Side)	Open Land
	South (Side)	Agricultural land
13.	**Open Space all around the building**	
	East (Front)	80.00 mtrs.
	West (Rear)	Nil
	North (Side)	40.00 mtrs
	South (Side)	03.00 mtrs
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

B. ***<u>On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view: -</u>***

Sl. No (01)	**Details (02)**	**Existing (03)**		**Recommendations (04)**
01.	Accessibility to the premises	The premises is abutting **5.50 mtrs** wide road on **Eastern** side of the premises. The road is hardened to carry the weight of the weight of 45,000 Kg's.		Adequate
02.	Number of Entrances	**01** entrance of **4.75 mtrs** wide.		-
03.	Number of Staircase	No of staircase	01	The Staircase must be maintained free from obstruction.
		Width of the staircase	1.15 mtrs	
		Width of threads	0.30 mtrs	
		Height of risers	0.15 mtrs	
		No of risers per flight	14 No's	
		Height of the hand drill.	1.10 mtrs	
		Head roof clearance	3.40 mtrs	

Scanned with OKEN Scanner

04.	Portable Extinguishers	Not Provided	**Not Complied** A. One ABC type extinguisher of 6 KG capacity for every 100 m^2. B. One CO_2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.
05.	Hose reel hose system	Not Provided	**Not Complied** One Hose Reel Hose near the staircase **(One hose reel hose system for every 1000 Sq. mtrs).** The **hose** reel hose of min 19 mm size and of 30.00 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing.
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	Not Provided	**Not Complied** The system should be connected to a booster pump of 450 LPM or of 5 HP capacity. **Further the system should be connected to an alternative source of power supply.**
07.	Diesel generator	Not Provided	**Not Complied** Diesel generator of 15 KVA capacities has been provided to supply alternative power supply.
08.	Escape routes	Not Provided	**Not Complied** Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
09.	Terrace tank over respective tower terrace.	Not Provided.	**Not Complied** The System should be connected to an overhead tank of 5,000 ltrs capacity. **(The water tank should be kept exclusively fire fight purpose)** **Note:** If the existing building is not capable of sustaining the weight of 5,000 / 10,000 ltrs tank capacity, provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS Column structure. If there is no option to provide even the above-mentioned overhead tank

Scanned with OKEN Scanner

			provision shall be made to provide underground water tank of capacity with submersible pump of 5-7 HP capacity.
10.	Fire Order (Fire safety plans)	Not displayed	**Not Displayed** A notice board indicating the action to be taken by the employees in case of any emergency should be displayed along with the telephone number of nearest fire station **Molakalmuru Fire Station i.e. 08198200100** and the telephone number of nearest ambulance service & Police station.
11.	No Smoking board	Not displayed	**Not Displayed** COTPA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both languages shall be prominently displayed at inside the entry / exit of each floor.
12.	Fire Siren	Not installed	**Not Complied** A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
13.	Nominate one fire Nodal officer.	Not Nominated	A fire nodal officer shall be nominated either from teaching or non-teaching staff.
14.	Fire Fighting Training	Not Imparted	At least 40% of the employee/staff should be got trained in basic firefighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore.
15.	***Fire precautionary measures: -*** A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to outside. G. As per Hon'ble Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.		

Scanned with OKEN Scanner

Hence here with recommending to issue "**Fire Advisory Certificate**" to ***"Sri Guru Mudukeshwara Higher Primary & High School"***, situated at ***Survey No: 55/1, Behind Indian Petrol Bunk, B.B Road, Rampura Village, Molakalmuru Taluk, Chitradurga - 577540*** is subjected to condition and compliance of the above recommendations in the column-4 of serial–B within 03 months and compliance to undersigned.

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life Safety will have to be complied with mandatory.

Submitted for favor of your kind perusal and necessary action.

Yours's faithfully

ಅಗ್ನಿಶಾಮಕ ಠಾಣಾಧಿಕಾರಿ
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು
ಅಗ್ನಿಶಾಮಕ ಠಾಣೆ. ಮೊಳಕಾಲ್ಮುರು.

Scanned with OKEN Scanner



ಶ್ರೀ ಓಂಕಾರೇಶ್ವರ ಸ್ವಾಮಿ ಪ್ರಸನ್ನ



SRI GURU MUDUKESHWARA VIDYA PEETA ®

Rudrakshimata, Omkareshwaranagara, K.K.pura-Rampura-577540 Molakalmuru (T), Chitrdurga (D),
PH: 9448979936 e-mail: sgmvidyapeeta@gmail.com

ಶ್ರೀ ಗುರು ಮುದುಕೇಶ್ವರ ವಿದ್ಯಾಪೀಠ (ರಿ)

ರುದ್ರಾಕ್ಷಿಮಠ, ಓಂಕಾರೇಶ್ವರನಗರ, ಕೆ.ಕೆ.ಪುರ, ರಾಂಪುರ-577540 ಮೊಳಕಾಲ್ಮೂರು ತಾ||, ಚಿತ್ರದುರ್ಗ ಜಿ||

Ref. NO. 07 Date: 08/10/2026

UNDERTAKING

To

The Central Board of Secondary Education (CBSE)

Affiliation Unit

New Delhi

Subject: Undertaking for Submission of Fire Safety Compliance Certificate

Respected Sir/Madam,

We, the Management of SRI MUDUKESHWARA HPS & HS School, RAMPURA hereby undertake that the Fire Safety Compliance Certificate of the school is under process with the competent authority.

At present, we are submitting the Fire Safety Recommendation Letter/Copy issued/recommended by the concerned authority as supporting evidence of the fire safety compliance process.

We hereby undertake that the final Fire Safety advisory/Compliance Certificate will be obtained from the competent authority and submitted/uploaded to the CBSE at the earliest, immediately upon its receipt.

We assure the Board that the school is committed to maintaining all prescribed fire safety measures and complying with the safety requirements and norms stipulated by CBSE and the concerned statutory authorities.

We therefore request the CBSE to kindly consider the recommendation copy submitted by us and permit us to proceed with the affiliation/compliance process. We undertake to submit the final certificate without delay.

Thanking you.

Yours faithfully,

For SRI MUDUKESHWARA HPS & HS School, RAMPURA

Signature:

Name: ONKARAIAH M G

Designation: Principal

Date: 08/10/2026

Place: RAMPURA

HEAD MASTER
Sri Mudukeshwara High School
RAMPURA- 577540
Molakalmuru(Tq), Chitradurga(Dt)

School Seal